



Heriot-Watt University
Research Gateway

What Does It Take to Go Net-Zero-CO₂? A Life Cycle Assessment on Long-Term Storage of Intermittent Renewables With Chemical Energy Carriers

Citation for published version:

Wevers, JB, Shen, L & van der Spek, M 2020, 'What Does It Take to Go Net-Zero-CO₂? A Life Cycle Assessment on Long-Term Storage of Intermittent Renewables With Chemical Energy Carriers', *Frontiers in Energy Research*, vol. 8, 104. <https://doi.org/10.3389/fenrg.2020.00104>

Digital Object Identifier (DOI):

[10.3389/fenrg.2020.00104](https://doi.org/10.3389/fenrg.2020.00104)

Link:

[Link to publication record in Heriot-Watt Research Portal](#)

Document Version:

Publisher's PDF, also known as Version of record

Published In:

Frontiers in Energy Research

Publisher Rights Statement:

© 2020 Wevers, Shen and van der Spek.

General rights

Copyright for the publications made accessible via Heriot-Watt Research Portal is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

Heriot-Watt University has made every reasonable effort to ensure that the content in Heriot-Watt Research Portal complies with UK legislation. If you believe that the public display of this file breaches copyright please contact open.access@hw.ac.uk providing details, and we will remove access to the work immediately and investigate your claim.



What Does It Take to Go Net-Zero-CO₂? A Life Cycle Assessment on Long-Term Storage of Intermittent Renewables With Chemical Energy Carriers

Jan Bernard Wevers¹, Li Shen^{1*} and Mijndert van der Spek²

¹ Copernicus Institute of Sustainable Development, Utrecht University, Utrecht, Netherlands, ² Research Centre for Carbon Solutions, School of Engineering and Physical Sciences, Heriot Watt University, Edinburgh, United Kingdom

OPEN ACCESS

Edited by:

Carlos Pozo,
University of Girona, Spain

Reviewed by:

Ralf Peters,
Julich-Forschungszentrum,
Helmholtz-Verband Deutscher
Forschungszentren (HZ), Germany
Edward J. Rode,
DNV GL, Norway

*Correspondence:

Li Shen
L.shen@uu.nl

Specialty section:

This article was submitted to
Carbon Capture, Storage, and
Utilization,
a section of the journal
Frontiers in Energy Research

Received: 17 January 2020

Accepted: 08 May 2020

Published: 23 June 2020

Citation:

Wevers JB, Shen L and van der Spek M (2020) What Does It Take to Go Net-Zero-CO₂? A Life Cycle Assessment on Long-Term Storage of Intermittent Renewables With Chemical Energy Carriers. *Front. Energy Res.* 8:104. doi: 10.3389/fenrg.2020.00104

The concept of net-zero-CO₂ power systems has gained increased attention by the EU goal to be a climate neutral continent by 2050. As potential pathways toward a net-zero-power system, this work analyzes future power systems based on intermittent renewable electricity with long-term storage through chemical energy carriers, so called Power-to-Fuel-to-Power systems, and a system based on the combustion of natural gas with 100% carbon capture and storage. The chemical energy carriers selected for electricity storage are hydrogen, methane and ammonia. Using life cycle assessment, we determine and compare the environmental impacts of 1 kWh of dispatchable electricity produced by the two pathways on seven impact categories. There was not one single pathway that had the most environmental benefits on all seven impact categories. Of the Power-to-Fuel-to-Power systems assessed the use of hydrogen for storage has the lowest environmental impact in all categories. Additionally, all the Power-to-Fuel-to-Power systems have a lower environmental impact on climate change, photochemical ozone formation and fossil resource depletion compared with the natural gas with carbon capture and storage system. The natural gas with carbon capture and storage system has a lower environmental impact on particulate matter formation, marine eutrophication and mineral resource scarcity. Our work is complemented by an analysis of pathways from a net-zero-direct-CO₂ to a life-cycle net-zero-CO₂-equivalent power system which is actually climate neutral, achieved by direct air capture of the residual CO₂ from the atmosphere. However, this leads to an increase in all other impact categories of 11% for the Power-to-Fuel-to-Power systems and 21% in the natural gas combustion with carbon capture and storage system. A system sizing study also highlights the very low capacity factors of the capital employed for electricity storage, raising the point of economic feasibility.

Keywords: energy storage, net-zero-CO₂-emissions, direct air capture, intermittent renewable energy supply, CO₂ capture and storage, chemical energy carriers, hydrogen, CO₂ based fuels

INTRODUCTION

The European Green Deal states that the European Commission aims to be the first climate neutral continent by 2050 (European Commission, 2019). The transition to a (near) zero-CO₂-emissions energy system is likely to depend on the availability of (i) vast amounts of emission-free electricity and (ii) the technologies and mechanisms to balance the large differences between intermittent Renewable Energy Supply (iRES) and end-user demand (Hertwich et al., 2014; Davis et al., 2018). Currently, gas and coal-fired power plants are used to balance the asynchronous production of the intermittent renewable electricity supply (iRES). In a future energy supply based on increased penetration of iRES, however, the long term (e.g., seasonal) storage of electricity is likely indispensable (Bussar et al., 2016).

Where there are many technologies proposed for short-term electricity storage, longer term (e.g., seasonal) storage of iRES is currently limited to storage in chemical energy carriers (e.g., through power-to-gas systems) and to a lesser extent pumped hydro. Pumped hydro is, however, only applicable when the topography is suitable and is best suited for storage in the order of days to weeks instead of weeks to months (Budt et al., 2016). The power-to-gas option usually starts with water electrolysis to produce hydrogen that can be stored in the subsurface directly or can react with CO₂ to produce methane or other hydrocarbons, which has the advantage of being able to use the existing natural gas infrastructure. Alternatively, hydrogen can react with N₂ to produce ammonia or ammonia derivatives (Grinberg Dana et al., 2016). Ammonia can be stored as a liquid at only 10 bars of pressure, which may be advantageous from the perspective of storage and energy required for pressurization. These chemical energy carriers can subsequently be used for the production of electricity, as described in Sutter et al. (2019), whence they are colloquially called Power-to-X-to-Power (P-X-P) systems.

Intermittent RES storage in both methane and ammonia would need large quantities of respectively CO₂ and N₂ as feedstock. As 80 percent of our atmosphere consists of N₂, it is relatively easy to obtain by an air separation unit (ASU) to produce pure streams of N₂ and O₂. Research on capturing CO₂ is mainly focused on the flue gasses from fossil fuel-fired plants as these contain high CO₂ concentrations and because it could reduce greenhouse gas (GHG) emissions of these plants if the CO₂ is subsequently stored (i.e., CO₂ capture and storage, CCS). In addition, direct air capture (DAC) of CO₂ is also being researched as a potential technology to reduce atmospheric CO₂ concentration and supply CO₂ (Wohland et al., 2018).


The interest for the combination of iRES with P-X-P systems is motivated by their potential to limit environmental impacts

compared to existing, fossil-based electricity production systems. To that end, such systems need to have a very low carbon footprint and preferably be net-zero-CO₂ (Davis et al., 2018; Sutter et al., 2019), as well as present limited other environmental burdens. An effective and comprehensive method to analyze the greenhouse gas and other environmental impacts of a technology or system is Life Cycle Assessment (LCA). Some LCAs of iRES storage are found in the literature: Oliveira et al. (2015) compared compressed air energy storage, pumped hydro, hydrogen and several types of batteries and showed that the type of electricity feedstock is decisive for the performance of storage systems. Reiter and Lindorfer (2015) and Zhang et al. (2017) did research on the global warming potential of Power-to-Gas, both for hydrogen and methane, but the conversion back to electricity was not included. Both studies showed that the system could only reduce environmental impacts if renewable electricity was used.

Research has also been done into the economics of power to gas technology as a technology to store intermittent renewable electricity, and found that it might be difficult to make profitable (Götz et al., 2016). Grinberg Dana et al. researched Power-Ammonia-Power (P-A-P) systems, but only on a technical level and did not include an environmental assessment (Grinberg Dana et al., 2016). Sutter et al. (2019) performed a first screening assessment, including the system design, efficiency, and exergy analysis of net-zero-CO₂ systems for iRES storage. They included Power-to-Fuel-to-Power, as well as Power-to-Fuel-to-Propulsion and investigated hydrogen, methane, methanol and ammonia as energy carriers. They tentatively concluded that only hydrogen makes energetic sense as an electricity-derived propulsion fuel, as the other systems showed cyclic energy efficiencies as low as ten percent with limited upside for exergy improvements. Methane and ammonia were found to have potential use for iRES based Power-to-Fuel-to-Power in addition to hydrogen as they have infrastructure based advantages concerning the method of storage.

Here, we build on the work performed by Sutter et al. and other researchers, by investigating the environmental potential and trade-offs of net-zero-CO₂ systems for the long term (seasonal) storage of intermittent renewable electricity with chemical energy carriers. This work limits itself to the energy carriers that were earlier found to be most interesting from an energy efficiency perspective, i.e., hydrogen, methane, and ammonia. The first objective of this paper is to design and size P-X-P systems based on hydrogen, methane and ammonia to fulfill the role of long-term iRES storage in the future European electricity market, taking into consideration (intermittent) electricity supply and demand profiles and the European Commission's 2050 goal to become a climate neutral continent. The second objective is to investigate environmental performance and trade-offs between the systems by looking at multiple environmental impacts. These trade-offs are key to understand for the selection and investment of future electricity systems in the European Union. Since the complete CO₂ abatement of natural gas-fired power plants through CCS is considered another route toward zero emission electricity, this alternative is compared to the P-X-P systems to provide a point of reference.

Abbreviations: P-X-P, Power-to-Fuel-to-Power systems; P-H-P, Power-to-Hydrogen-to-Power system; P-M-P, Power-to-Methane-to-Power system; P-A-P, Power-to-Ammonia-to-Power system; NGCC, Natural Gas Combined Cycle; CCS, Carbon Capture and Storage (system); DAC, Direct Air Capture of CO₂; ACC, Ammonia Combined Cycle; LCA, Life Cycle Assessment; GHG, Green House Gasses; iRES, intermittent Renewable Electricity Supply; CWE, Central West Europe; ASU, Air Separation Unit; PEMFC, Polymer Electrolyte Membrane Fuel Cell; PEMEC, Polymer Electrolyte Membrane Electrolysis Cell.



METHOD

As stated above, this work aims to investigate the environmental performance of future power systems, coupling iRES with long-term electricity storage. In order to quantify this performance, we integrated two methods: simplified power systems modeling to determine P-X-P system sizes given real iRES production and projected electricity demand profiles and an attributional LCA following ISO14044 standards (ISO, 2006; Weidema, 2018). The method section follows three steps, visualized in **Figure 1**, in which order the research was performed. First, goal and scope are defined for the system design and the LCA including the need for a new functional unit. Second, the system design model and the Life Cycle Inventory (LCI) model are explained. Third, the approach to the dimensioning of the systems using a customized electricity supply-demand model is explained.

Goal and Scope Definition


The goal of the LCA is to investigate the environmental impacts of different coupled iRES/P-X-P systems, subject to the constraint of net-zero-CO₂-emissions. This pushes the boundaries of traditional LCA, where CO₂ emissions are one of the investigated stressors (outputs), rather than constraint to zero (input). The goal is furthermore to understand the environmental trade-offs between the chemical energy carriers with respect to selected environmental indicators (see section Environmental Impact Categories), and the root cause of these stressors, to allow for policy and decision making.

With respect to scope definition, the electricity market in Europe is divided in seven Wholesale Electricity Markets where electricity is traded over national borders (European Commission, 2018). In this study, Central West Europe (CWE) was chosen as the geographical focus. The CWE market

constitutes Austria, Belgium, France, Germany, the Netherlands and Switzerland. The CWE was selected because it has a large interconnection capacity between the member states and it uses a more advanced method to calculate the optimal use of this capacity, called flow-based market coupling (CWE NRAs, 2015; Amprion GmbH, 2018). Besides the good interconnection, these countries are located in a geographical position where seasonal storage is expected to become of importance (see also the iRES production profiles presented in section System Dimensioning and the Storage Requirements) and therefore make a useful case study.

Function and Functional Unit

Electricity is the main output function. However, 1 kWh of electricity produced by a renewable intermittent source cannot be directly compared with 1 kWh of electricity directly delivered from a thermal power plant as is still often done. The latter can generate and dispatch electricity according to demand, by cycling the plant up and down (Heuberger et al., 2016; van Der Spek et al., 2018). Conversely, a system with intermittent renewable electricity production without any electricity storage is not demand responsive, since its production is subject to the availability of wind, sun, or other natural phenomena (wind parks are however able to reduce production, so-called curtailment). The functions under discussion are noticeably different. Thermal power plants have the function of providing electricity, but also of grid balancing and providing inertia (Brouwer et al., 2015; Mac Dowell et al., 2017). iRES only fulfills the function of electricity production. Therefore, we here propose the functional unit of 1 kWh of *dispatchable* electricity. We define that electricity production in a system is dispatchable if it can respond to a given demand curve. As shown in **Figure 2**, this implies that iRES systems need to include an electricity storage function to provide



grid balancing. This storage is only used if the intermittent supply does not match the demand profile at a point in time.

Net-Zero-Direct-CO₂-Emission Constraint

The systems under consideration were configured in such a way, that their direct CO₂ emissions to the atmosphere were set to zero: either the system does not emit direct CO₂ by nature (e.g., renewable power-to-hydrogen-to-power) or the system is expected to take up the same amount of CO₂ as is emitted directly, for instance through CO₂ capture from a combustion process and/or the air. The systems thus have net-zero *direct* CO₂ emission. The net-zero-CO₂ constraint was here enforced because given European and global climate ambitions (IPCC, 2014, 2018; European Commission, 2019), it is virtually certain that iRES with P-X-P is needed to achieve a net-zero-CO₂ world.

Product Systems

Based on the defined function, functional unit, and the net-zero-direct-emission constraint, three P-X-P systems and two reference systems were analyzed in this study:

- Power-to-Hydrogen-to-Power (P-H-P)
- Power-to-Methane-to-Power (P-M-P)
- Power-to-Ammonia-to-Power (P-A-P)
- Future reference system: Natural gas combined cycle with carbon capture and storage complemented with direct air capture to mitigate residual direct CO₂ emissions (CCS)
- Current reference system: Natural gas combined cycle (NGCC).

For the P-X-P systems, a common first step in the chemical storage of intermittent renewable electricity is the production of hydrogen through the electrolysis of water. Proton Exchange Membrane Electrolysis Cells (PEMEC) were assumed in this research as they are projected to be the dominating technology in the near-future, replacing Alkaline Electrolysis Cells (AEC) (Schmidt et al., 2017), among others due to their increased operational flexibility.

The second step is the long-term storage of hydrogen. This can be done mechanically (high pressure, cryogenic), chemically (via Methane, Methanol or Ammonia) or through physisorption (Fullerenes, Nanotubes) (Niaz et al., 2015). Here, we assumed the same chemical energy carriers for storage as earlier done in Sutter et al. (2019): compressed hydrogen (100 bar), methane and ammonia. Methanol was excluded from this research because of the lower net system efficiency compared to methane and the fact that it lacks the inherent benefit of the existing natural gas infrastructure (Sutter et al., 2019). Methanol could have the potential benefit of allowing a coupling to the chemistry sector, but sector coupling is outside the scope of this paper and was not considered here. Ammonia was here included because it is a carbon free synthetic alternative to methane and hydrogen and thereby naturally closer to the goal of a net-zero-CO₂-emission system.


Two reference systems were chosen: first, a future reference system where an NGCC is fully abated by CCS, both post-combustion capture and DAC to conform to the net-zero-CO₂ constraint. This reference scenario was chosen because the use of natural gas in combination with CCS is often seen as an alternative option to decarbonize electricity supply. Second, a current reference system where the dispatchable electricity was supplied by an unabated Natural Gas Combined Cycle (NGCC), to provide a status-quo benchmark.

Environmental Impact Categories

The LCA evaluated the environmental impact of energy systems in seven impact categories (Table 1) that represent relevant environmental stressors to land, air, and water, human health and resource depletion. Based on the goal of the LCA that environmental trade-offs should be understood for the net-zero technologies, the choice of impact categories should not be limited to only carbon emissions. The seven impact categories were chosen because they provide a balanced view of important resources depletion (e.g., mineral resources and fossil fuel depletion) and the environmental impact associated with the direct emissions of the fossil fuel-fired thermal power plants,

TABLE 1 | Impact categories included in this LCA.

Impact category	Characterization factor	Short description	Example of relevant LCI data	Unit
Climate change (CC)	Global warming potential	Impact on radiative forcing of the atmosphere	CO ₂ , N ₂ O, CH ₄ , SF ₆ , CF ₄ , CFCs	kg CO ₂ eq.
Photochemical ozone formation (POF)	Photochemical oxidant formation potential	Summer smog, formation of reactive chemical compound by sunlight	NO _x , NMVOC's	kg NO _x eq.
Particulate matter formation (PMF)	Particulate matter formation potential	Emission of aerosols with negative effect on human health	NO _x , NH ₃ , SO ₂ , PM2.5	kg PM2.5 eq.
Terrestrial acidification (TA)	Terrestrial acidification potential	Emissions of acid-forming substances	NO _x , NH ₃ , SO ₂	kg SO ₂ eq.
Marine eutrophication (ME)	Marine eutrophication potential	Excessive supply of nutrients	NO ₃ ⁻ , NH ₃ , NH ₄ ⁺	Kg N eq.
Mineral resource scarcity (MRS)	Surplus ore potential	Depletion of minerals	Fe, Ni, Al, Cu	Kg Cu eq.
Fossil resource scarcity (FRS)	Fossil fuel potential	Depletion of fossil resources	Oil, natural gas, coal	Kg oil eq.



such as NO_x, particulate matter and SO₂ (see **Table 1**). The life cycle impact assessment method used was the Hierarchist perspective in the ReCiPe 2016 methodology. The underlying assumptions and midpoint categorization factors can be found in Huijbregts et al. (2016).

System Design and Life Cycle Inventory Analysis

This section discusses the system designs and the key design parameters, followed by the methods applied for system dimensioning.

Future Reference System (CCS): Natural Gas Combined Cycle (NGCC) With Carbon Capture and Storage (CCS) and Direct Air Capture (DAC)

The future reference system is illustrated in **Figure 3**. Natural gas is supplied to an NGCC, where it is combusted to produce

electricity. In Central West Europe, natural gas is supplied from different countries. The assumed NG basket is provided in the **Supplementary Information**.

Ninety-five percent of the CO₂ is captured using integrated post combustion CO₂ capture, that draws off steam from the steam cycle for sorbent regeneration. The specific energy requirement for post-combustion capture shows a sharp increase if the capture rate exceeds 90% (Mletzko et al., 2016), whereas the specific energy requirements for direct air capture are constant. The ratio of post-combustion capture and DAC where total energy losses are at their minimum was found to be 95% post-combustion capture and 5% DAC respectively. The captured CO₂ is compressed, transported and stored in a geological formation where it remains indefinitely if the formations are properly engineered and serviced (Bai et al., 2016). In this work, the potential leakage risk is considered to be negligible within the temporal scope

of the impact assessment (100 years) and is not taken into account.

The electricity requirement for DAC, which is 0.25 kWh/kg captured CO₂ (Wohland et al., 2018), can be directly obtained from the power produced within the system. The DAC heat demand, 1.75 kWh/kg CO₂ captured (Wohland et al., 2018), is also obtained from the system, where we assumed that the low temperature heat (~100°C) is produced using an industrial heat pump with a Coefficient Of Performance (COP) of 2 (Arpagaus et al., 2018).

Power-to-Hydrogen-to-Power (P-H-P)

Figure 4 shows the P-H-P system where there are no direct CO₂ emissions. The energy that is needed for the production and compression of hydrogen is assumed to be supplied by

intermittent renewables and thus the P-H-P system only runs when there is surplus iRES. Hydrogen production was assumed by PEMEC at 30 bar (Carmo et al., 2013) with subsequent compression to 100 bar (HyUnder, 2014). Hydrogen storage is expected to be facilitated underground in a salt cavern as they are present in CWE, have high storage capacities and have high flexibility regarding injection and withdrawal (IEA, 2012; Michalski et al., 2017). Considering the fact that it is not always possible to build the electrolyser exactly on top of the underground storage location, a transport distance of 50 km was assumed between hydrogen production and storage as well as between the storage location and the Polymer Electrolyte Membrane Fuel Cell (PEMFC) facility. Hydrogen losses due to transport are 5 times higher compared to natural gas in steel pipes, but when polyethylene pipelines are used the




FIGURE 4 | System diagram of the P-H-P system: Yellow lines represent electricity, blue is hydrogen.




FIGURE 5 | System diagram of the P-M-P system: Yellow lines represent electricity, blue is hydrogen, black is CO₂, green is methane and red is heat.





FIGURE 6 | System diagram of the P-A-P system. Yellow lines represent electricity, blue hydrogen, orange nitrogen and purple ammonia.

losses are merely 0.0005–0.001% of total transported volume (Haeseldonckx and D’haeseleer, 2007). For this research a loss of 0.00075% of total transported volume was assumed.

Power-to-Methane-to-Power (P-M-P)

The P-M-P system comprises of the methane production and the consecutive methane incineration in an NGCC with CCS in order to meet the net-zero CO₂ constraint (Figure 5). The technical specifications of the NGCC are identical to the NGCC described in the reference system, including the capture efficiencies, residual direct CO₂ emissions are recaptured from the air using DAC. The short-term hydrogen and CO₂ storage were added so that the methanation plant and DAC unit can run at a high capacity factor (thus also for the periods without iRES, see section System Dimensioning and the Storage Requirements), which is economically favorable. The produced methane was expected to use existing natural gas infrastructure for transport and storage, with an assumed distance from production to storage and storage to use of 50 km to account for the infrastructural needs and methane leakage.

Methane can be produced by hydrogenation of CO₂ and is widely researched in literature (Hutchings, 2002; Müller et al., 2011).




Here, we assumed catalytic methanation as this is the only technology that is available on the required scale and data on this process is readily available (Götz et al., 2016). Catalytic methanation is a highly exothermic process and the excess heat, with temperatures exceeding 300°C, can be used for the heat and electricity demand of the DAC unit. If the heat exceeds the demand of the DAC unit, it can be used for other industrial purposes and was considered a useful by-product, replacing heat

produced by an industrial Combined Heat and Power unit which combusts fossil fuels.

Power-to-Ammonia-to-Power (P-A-P)

Hydrogen for ammonia synthesis is nowadays produced by the reforming of natural gas. Here, however, the hydrogen is assumed to be produced by PEMEC. In contrast to the CO₂ cycle that is added in the P-M-P system, the P-A-P system has a nitrogen cycle. Ammonia is produced from hydrogen and nitrogen in the reaction shown below in the Haber-Bosch process.



Ammonia synthesis needs a high temperature and pressure, although there is on-going research done on catalysts that could operate under atmospheric conditions (Vojvodic et al., 2014). A pure stream of nitrogen is required for this reaction which is produced by an ASU. In analogy to the methane system, the system in Figure 6 includes short-term hydrogen storage to increase the capacity factor and decrease the size of the ammonia production plant. Therefore, the electricity supply to the ASU and ammonia production plant have to be dispatchable and cannot fully originate from iRES. In times when iRES is limited the electricity is supplied from the ammonia combined cycle (ACC). The ammonia combined cycle is a new technology that has been researched and is expected to be technologically feasible (Institute for Sustainable Process Technology, 2017), although many uncertainties remain on its (environmental) performance (see discussion in section Combustion of Ammonia). Ammonia is stored as a liquid in tanks that are on site and under 10 bars of pressure.

Technology Performance Assumptions

The key technology performance assumptions are summarized in Table 2. The calculated mass and energy flows, the outputs of

TABLE 2 | Main technology performance assumptions used in this study.

Key processes	Electricity input requirement MWh/t	Heat input requirement MWh/t
Direct air capture ^a	0.25	1.75
Methane synthesis ^b	0.33	-3.008
Ammonia synthesis (incl. ASU) ^c	0.667	n/a
H ₂ compression from 30 to 100 bar ^d	0.707	n/a
Conversion efficiency (in terms of LHV)		
H ₂ production (PEMEC at 30 bar) ^e		70%
PEMFC ^f		60%
NGCC w/o CO ₂ capture ^g		59%
NGCC with CO ₂ capture ^h		50.2%
Ammonia Combined Cycle ⁱ		53.1%
Post combustion CO ₂ capture rate ^k		95%

^aWohland et al. (2018), ^bMüller et al. (2011), ^cValera-Medina et al. (2018), ^dAspen Plus simulation assuming 72% isentropic efficiency, ^eGötz et al. (2016), ^fPolymer Electrolyte Membrane Fuel Cell (US Department of Energy, 2017), ^gIEA (2012), ^hbased on IEA (2012), adjusted to include 95% capture efficiency instead of 90%, ⁱInstitute for Sustainable Process Technology (2017), ^kEnergetically optimal capture efficiency per inhouse calculations. From a 95% capture rate onward, the impact of CO₂ capture on net NGCC efficiency is higher if PCC is assumed instead of DAC. n/a, not applicable.

system designs step (sections System Dimensioning and System Dimensioning and the Storage Requirements), were used as the input for the life cycle inventory modeling. The detailed foreground data that was used as LCI data is presented in the **Supplementary Information**, the background data was obtained from the EcoInvent database v3.5.

System Dimensioning Storage and Component Sizing Model

One of the critical parameters in our system analysis (see also section Hourly vs. daily vs. weekly data points) is the percentage of iRES that is to be stored to achieve the desired function of dispatchable electricity. Here, an optimization model was applied, using electricity supply and demand data to determine the amount of electricity storage needed and therefore the size of the different systems' components. We acknowledge this is a simplification because our systems would in reality not be stand-alone, but be part of a complex power system including many different types of electricity generators, storage options, and country interconnections (e.g., Zappa et al., 2019). This simplification, however, allows the comparative LCAs of the systems studied that we seek to undertake here.

To determine the dimensions of the different components and flows of the systems, an electricity supply-demand model was specified in Python. This model calculated, based on estimated future demand and real iRES production curves using Equation (3) (see also section Electricity Supply and Demand Data), the necessary storage capacity of the system using Equation (4) (here

presented for hydrogen):

$$U_t - P_t = D_t - S_t * SF \quad (3)$$

$$H_t = H_{t-1} + P_t * \eta_{el} - \frac{U_t}{\eta_{fc}} \quad (4)$$

Where, D_t and S_t are the demand and supply of electricity at time t , P_t , H_t , and U_t are the production, storage, and use of hydrogen at time t , η_{el} and η_{fc} are the electrolyser and fuel cell efficiencies, and SF is the storage systems scaling factor.

The model minimizes the total iRES production needed to fulfill a given demand profile as a function of the storage system scaling factor. This method of minimization prevents the model from producing and using the chemical energy carrier at the same time, which in real life would be unlikely [see Equation (5)]:

$$\text{Minimize} \sum_{t=1}^{365} (P_t (SF)) \quad (5)$$

$$\text{s.t. } H_t \geq 0 \quad (6)$$


$$H_0 = H_{end} \quad (7)$$

Equations 6 and 7 are constraints stating that the chemical energy stored cannot become negative and that the energy stored at the end of the year equals the energy stored at the beginning. This is added so the system does not get any "free" energy, as the system starts with a certain amount of stored energy.

Electricity Supply and Demand Data

The future demand curve for the supply-demand model was taken from Zappa et al. (2019). It is based on assumptions in the EU Energy Roadmap 2050 on increased electricity demand for heating (500 TWh y^{-1}) and transport (800 TWh y^{-1}) in the EU (European Commission, 2012). Zappa et al. used the 2015 demand profiles for EU countries from the ENTSO-E database and added the increased demand for heating and transport (Zappa et al., 2019). Here, the demand profiles of the countries constituting Central West Europe (CWE) where added up to obtain a demand profile for the total CWE region. This means we made the simplifying assumption that there will be unlimited transmission capacity between these countries. Our systems were not expected to fulfill the demand for the complete CWE region, but were designed to have a maximum capacity of 1 GW (the size of a typical large-scale thermal power plant). Therefore, the CWE demand curve was scaled such that the maximum total supply it reached was 1 GW.

The iRES production profiles were constructed using the "Renewables.ninjas" database (Pfenninger and Staffell, 2016; Staffell and Pfenninger, 2016). For wind production, the "long-term future fleet" datasets were used; for the solar energy production, the MERRA-2 dataset was used. These datasets contain 30 years (1985–2015) of hourly values for the capacity factor of wind and solar production and are available per country. To predict the total production of wind and solar energy in CWE in 2050 these capacity factors were multiplied by the planned installed capacity in 2050 in these countries, based on the "Energy, Transport and GHG emissions Trends 2050" from the



EU (European Commission, 2016). The wind and solar profiles of the CWE countries were combined to obtain the iRES supply profiles of the whole CWE. Because the used iRES supply dataset includes 30 years of weather profiles we obtained 30 different potential CWE iRES supply profiles. The system dimensions were determined such that the systems can operate in all 30 years. Both the demand and supply profiles are can be found in detail in the **Supplementary Information**.

RESULTS

System Dimensioning and the Storage Requirements

Figure 7 shows the storage requirements resulting from the projected supply-demand optimization for one exemplary year. The left **Figure 7A** shows the modeled daily supply and demand of the P-M-P system using the 2015 meteorological data and the required dispatch (in GW) of the electrolyser and the NGCC. The system’s maximum hourly consumer demand was set to 1 GW (see section Electricity Supply and Demand Data). Because the hourly data points were aggregated into daily points, the maximum of the daily averaged data is lower than 1 GW (763 MW). **Figure 7A** also shows that for the P-M-P system, as expected, the electrolyser is operated more in the summer months, whereas the NGCC delivers more electricity in the winter months. This is reflected in the fluctuations of the total amount of energy storage required. **Figure 7B** shows that the systems indeed provide seasonal electricity storage, as the stored amounts of energy carriers dip before, and peak after the summer. Exemplary profiles for the P-H-P and P-A-P systems can be found in the **Supplementary Information**.

Table 3 shows the results of the key design parameters based on the required electricity storage capacity for all three P-X-P systems. The capacity factors of the electrolyser are around

17% for all three systems, where the capacity factors of the power plants and fuel cell are around 8%. These low capacity factors show that a large part of the electrolyser capacity remains unused during the year, which may have implications for economic feasibility. Although economics are outside the scope of this paper, it is worth noting that PEMECs are expected to have a capital cost between 250 and 1270 €/kW in 2030 (FCH JU, 2015) and that such low capacity factors would imply inefficient and therefore expensive use of installed capital. Similarly, construction of a power plant that operates <10% of the time may be expected to be unprofitable (unless the power plant has surpassed its economic lifetime, or if it would be possible to use the remaining capacity of the NGCC for the combustion of natural gas with CCS, net-zero hydrogen or ammonia).

In both the P-M-P and P-A-P systems there is still the need for a relatively sizeable hydrogen storage of 330–350 GWh. This results from the assumption of at least 90% capacity factors of the methane and ammonia production plants (which was made taking into account the economic feasibility of methanation and ammonia production). If this constraint is deleted, the hydrogen storage size would greatly reduce. However, this would, in turn, lead to an increase in the size and decrease in the capacity factor of the methane and ammonia production, indicating a trade-off in system design where a full economic analysis would be required to determine a potential optimum.

For the P-M-P system, if the 2015 weather data is used, the methane storage fluctuates between 50 GWh and 350 GWh (see **Figure 7**). However, the methane storage needed for the P-M-P system to function over the complete 30 years of weather data in **Table 3** is 859 GWh. This shows that there is a large difference in storage capacity requirement over the years and that this strongly depends on the production profile of the renewable electricity.

TABLE 3 | Key design parameters as the output from the system dimensioning model.

Product systems	P-H-P	P-M-P	P-A-P
Input values for the system dimensioning model			
Estimated electricity demand (GWh/yr)	4628	4628	4628
Calculated iRES production (GWh/yr)	5500	5647	5628
Intermediate outputs			
Electricity directly to grid (GWh/yr)	4221	4254	4250
Electricity stored (GWh/yr)	1279	1392	1378
Electricity from Power plant/fuel cell (GWh/yr)	407	373	377
Roundtrip efficiency	31.8%	26.8%	27.4%
Fraction of demand delivered by power plant/fuel cell	8.8%	8.1%	8.1%
Fraction of electricity stored	23.2%	24.7%	29.8%
Capacity factor electrolyser	16.6%	17.3%	17.2%
Capacity factor Methane/Ammonia synthesis plant	n.a	92.5%	91.6%
Capacity factor Power plant/Fuel cell	8.4%	7.8%	7.9%
Optimized capacities of key components			
Electrolyser size (MW)	881	859	913
Power plant/Fuel cell size (MW)	553	548	549
Methane/Ammonia plant (MW)	n.a	110	110
Hydrogen storage (GWh)	1140	347	330
Methane/Ammonia storage (GWh)	n.a	859	763

It also shows the capacity factor and minimum size of all components and storage media necessary in order to operate in all 30 years of weather data (1985–2015) investigated. The input values and intermediate outputs are average values over the 30 years of weather information used. The Optimized capacities are absolute (maximum required) capacities. n.a., not applicable.

For the P-X-P systems, the total required storage is ~ 1.1 TWh for the dispatchable capacity of 1 GW. With the maximum electricity demand in the CWE region in 2050 predicted to be 385 GW (Zappa et al., 2019), 424 TWh of electricity storage is needed to deliver all electricity in the CWE region in 2050. To put this into perspective, there is currently around 640 TWh of natural gas storage in the CWE region (Gas Infrastructure Europe, 2018). If natural gas usage declines in the coming decades and if the geology allows it, this excess storage capacity could be used for hydrogen or synthetic methane instead (DBI-GUT, 2017).

Finally, the amount of electricity that goes through storage will influence the technical and environmental performance of the systems. If a higher percentage of renewable electricity needs to be stored, it will decrease the overall system efficiency due to the energy losses of storage. Consequently, the required sizes of the different components will also be affected. This point is further discussed in section Data Uncertainty.

Results of Environmental Life Cycle Assessment

The system sizing is fed into the LCA, here presented in the following three subsections. First, the overall comparison of

the environmental impacts is addressed to allow discussing the environmental trade-offs between the investigated P-X-P systems (with net zero direct emissions) and the two reference systems (i.e., NGCC and fully abated NGCC). Second, each impact category will be interpreted in detail. Last, the environmental impacts are interpreted based on the geographical scopes of the value chain.

Overview Comparison of Environmental Impacts

Figure 8 shows the life cycle environmental performance of the five electricity supply systems studied. Comparing the two NGCC reference systems, the figure shows that fully abating the direct CO₂ emissions of the NGCC system (“CCS” in **Figure 8**) reduces its life cycle climate change (CC) impact by around 70% compared to the unabated NGCC system, but it leads to an increased impact on all other impact categories. The 70% of climate change reduction is in the range which was found in earlier studies by Corsten et al. (2013) and Singh et al. (2011), where CCS implementation to an NGCC decreased CO₂-equivalent emissions by 60–80% while increasing all other impacts. Note that the CCS system in this study assumed a higher CO₂ capture rate (95%) at the NGCC compared to the systems analyzed by Corsten and Singh (90% capture rate); also, in our study DAC was assumed to reduce the remaining 5% of emissions in the foreground. The noticeable increase ($\sim 25\%$) in fossil resource scarcity is largely due to the reduced efficiency of the NGCC and thus the increased use of natural gas, which was also observed by the aforementioned authors.

Compared to the two NGCC systems, the P-X-P systems offer substantial environmental impact reductions in three categories out of seven, namely, 80% reduction in climate change (CC), 40–50% reduction in photochemical ozone formation (POF) and 90% reduction in fossil resources scarcity (FRS). However, the P-X-P systems have higher impacts on PM formation (PMF), marine eutrophication (ME) and mineral resource scarcity (MRS), than the NGCC systems. For terrestrial acidification (TA), the NGCC case has the lowest impact whereas the P-A-P system has the highest impact. The detailed interpretation of each impact category will be provided in the following.

Breakdown by Key Processes

Figure 9 shows the breakdown of the LCA results by key processes for each environmental impact category. The natural gas input includes the extraction and transport of natural gas. The renewable electricity process includes the production and installation of PV and wind capacity. Infrastructure therefore does not include PV and wind capacity but only the NGCC, ACC, fuel cell, electrolyser, and storage assets.

Impacts resulted from the emissions from the fuel input, being either natural gas or renewable electricity, dominate the environmental impact in the systems. The current reference NGCC system is the exception where the direct emissions are responsible for the largest share (80%) of the CC (see **Figure 9A**), 91% of PMF (**Figure 9C**) and 47% of the POF (**Figure 9B**).

The direct emissions at the plant also contribute a significant fraction to the impacts of POF (16%) and PMF (18%) for the P-A-P system due to unburned ammonia and large quantities of NO_x




FIGURE 8 | Comparison of cradle-to-factory gate environmental impact of 1 kWh dispatchable electricity for the studied cases on seven selected impact categories. Results normalized to the system with the highest impact (set to be 100%). CC, Climate Change; POF, Photochemical Ozone Formation; PMF, Particulate Matter Formation; TA, Terrestrial Acidification; ME, Marine Eutrophication; MRS, Mineral Resource Scarcity; FRS, Fossil Resource Scarcity.

in the flue gas (See **Figures S14, S15**). Improving the combustion rate of ammonia could lower this high impact, but the full combustion of ammonia is known to be challenging due to its low flame speed (Institute for Sustainable Process Technology, 2017).

The direct emission of ammonia at plant in the P-A-P system is also responsible for 43% of the terrestrial acidification impact (see **Figure S16**), because ammonia is a strong acidification gas with a characterization factor of 1.96 kg SO₂ eq./kg ammonia. The unburned ammonia and the rate of NO_x emissions at ammonia combustion are however a source of large uncertainty, and they are therefore further addressed in section Combustion of Ammonia.

By adding CCS and DAC to the NGCC the climate change (**Figure 9A**) impact decreases by 70%. The CC impact of CCS system is dominated by the background processes, mainly originated from the production of natural gas. Due to the decreased efficiency of the NGCC with CCS, the natural gas input per kWh produced, and with it the methane emissions from natural gas production and transport losses (fugitive emissions), increases. This increase in methane emissions therefore slightly negates the positive effects of the CO₂ capture and storage.

For the three P-X-P systems, the impacts from the production of renewable electricity dominate (89–98%) in all seven categories. The impacts are associated with the manufacturing of PV panels and wind turbines for which aluminum and copper are mined and the manufacturing processes use fossil-fuel based energy. For instance, for climate change, 47% of the impact is caused by coal-based electricity; for fossil resources scarcity, 40–45% of the impact is caused by hard coal, 25–30% is caused by natural gas and ~20% is caused by crude oil.

For the two reference systems, the impacts from natural gas production are mainly contributed by the fugitive methane emissions during long-distant pipe transportation, electricity needed for compression and emissions during natural gas extraction.


The impact of other infrastructure (electrolyser, storage of fuel, fuel cell and natural gas/ammonia combustion facility) of the P-X-P systems is relatively low. It only contributes 1–5% of the life cycle impact, with the exception of the mineral resource scarcity impact (9–12%). Infrastructure impact is highest in the CCS system, mainly due to the CO₂ pipeline and storage. A breakdown by substance for all impact categories can be found in the **Supplementary Information**.

Geographical Origin of the Environmental Impacts

One of the key findings based on the breakdown results is that the environmental impacts of the net-zero electricity systems are strongly associated with mining of aluminum and copper, the manufacturing of PV panels and wind turbines, and the extraction and transport of natural gas for the NGCC-based systems. If the EU wants to minimize the impacts of these net-zero electricity systems it is important to pay attention to these environmental hotspots occurring outside of the EU.

Figure 10 shows the geographical origin of the environmental impacts of the two net-zero electricity systems: CCS and P-M-P. The other two P-X-P systems resemble much to P-M-P systems in terms the geographical distribution of the impacts.

In the CCS system, the climate change impact resides for more than 60% outside of the EU borders, mainly due to natural gas imported from Russia (45% of total). The P-M-P system has a larger uncertainty in the geography than the CCS system as more of the impact has an unknown location, but still more than 48% of the climate change impact resides outside of the EU borders, as most PV panels today are manufactured in China. For photochemical ozone formation we see a similar trend, where the P-M-P system has at least 36% of the impact originated outside of EU borders.




DISCUSSION

Hourly vs. Daily vs. Weekly Data Points

In the modeling approach it was chosen to aggregate the hourly supply and demand data into daily data points. Thereby, the P-X-P systems do not provide to balance intraday fluctuations

but rather fulfill their long-term storage role. The share of the electricity demand that is provided by the storage was 8–9% in contrast to 12–13% if the hourly data points would have been used. Rodriguez et al. found that if 100% renewable production in Europe, assuming unlimited interconnection and



using hourly data, almost 15% of demand needs balancing (Rodríguez et al., 2014).

To focus even more on seasonal energy storage, weekly aggregated data points could have been modeled as well, which would have resulted in only 4.5–5.5% of electricity demand passing through storage. As a consequence, less iRES passing through storage would further reduce the climate change impact of the P-X-P systems by 7–8% (see also the sensitivity analysis in section Data Uncertainty). However, it would also reduce the capacity factor (e.g., to ~4 and 2%) of the electrolyser and fuel cell/NGCC/ACC, making the system even less economically attractive. This highlights a difficult trade-off between the total environmental impact and the economic feasibility for chemical energy storage used for net-zero electricity supply.


Data Uncertainty

A one-way sensitivity analysis was conducted to identify the sensitive system parameters and assumptions. The results are shown in **Figure 11** for the four net-zero electricity supply systems for climate change. Other impact categories largely resemble climate change as most environmental impacts are concentrated in the renewable electricity supply and natural gas supply.

The CCS system is the most sensitive to changes related to the natural gas supply and consumption, given that the natural

gas supply chain is the largest source of GHG emissions in the background system. The uncertainties lie mainly in the fugitive methane emissions that take place during production and transport, and in the efficiency with which natural gas is converted to power in the NGCC. For the supply chain, the origin of the gas plays an important role. There is a large potential to improve, since for example Russian gas is known to lose 0.23% per 1,000 km during transport (Dones et al., 2005). The efficiency of gas turbines is also a sensitive parameter for the CCS system (see **Figure 11**). However, the NGCC is a mature technology and it is not expected that the efficiency of gas turbine will substantially improve (i.e., more than single percentage points) unless breakthrough technologies reach the market.

The P-X-P systems are most sensitive to changes in the environmental burden of the renewable electricity input (iRES impact), as also evident by the breakdown results that renewable electricity production is the most important contributor (section Breakdown by Key Processes). Interestingly, an increase in the “percentage of iRES stored” increases the climate change impact. This is expected as the storage system increases the renewable electricity requirement because of the increased energy losses in the conversion processes and the need for more infrastructure. It is therefore key to limit the need for electricity storage to limit the life cycle impacts, if possible, e.g., by means of demand side management.



Combustion of Ammonia

One further uncertainty that was highlighted in the results is the large scale combustion of ammonia for energy purposes (see Section Breakdown by Key Processes). This is a concept recently received much attention but not yet extensively researched (Institute for Sustainable Process Technology, 2017; Yapicioglu and Dincer, 2019). Many key technical and environmental performances of ammonia combustion such as the direct emissions of NO_x and unburned ammonia are still uncertain.

Estimates for NO_x emissions in flue gas from ammonia combustion range from 20 to 2,300 ppm, depending on various parameters such as equivalence ratio's¹, inlet temperatures, fuel additives and combustion pressures (Nozari and Karabeyoğlu, 2015; Valera-Medina et al., 2018). We here chose a value of 300 ppm NO_x, six times higher than in a *natural gas*

¹Equivalence ratio: the ratio of fuel vs. oxidizer. An equivalence ratio > 1 means that the blend has more fuel than can be burned based on the stoichiometric ratio.




FIGURE 12 | Change in environmental impact per kWh dispatchable electricity if DAC is also used to fully negate the GHG emissions of background processes. The bars show the increased environmental impacts of the zero GHG emission systems; the diamonds give original values from the net-zero-direct-CO₂-emissions systems in **Figure 8**. Arrows show whether there is an increase or decrease of the impact compared to the case where only the foreground emissions were abated. A value of 100% represents the system with the highest environmental impact on that impact category.

combined cycle, because it is expected that the different burning characteristics of ammonia will always lead to relatively high NO_x emissions (Nozari and Karabeyoğlu, 2015). For the amount of unburned ammonia we chose 30ppm, which is based on research from Kobayashi et al. (2019) and Kurata et al. (2019). Many studies about ammonia combustion do not report on unburned ammonia emissions at all (Valera-Medina et al. and Nozari et al.).

Background Inventory for Future Production Systems

This paper analyzed future energy supply systems and used predictions of future electricity demand, renewable electricity supply and technological parameters. However, the database used for the background inventory, EcoInvent database version 3.5, is based on the current average technology level. The impacts from the background inventories are expected to reduce in the future on the path of our energy transition toward more sustainable resources. The CO₂ emissions associated with PV panel production and natural gas supply will hopefully change for the better as we move to a low carbon world. To analyze a future energy system by using dynamic projections of life cycle inventory data is outside the scope of this research.

Net-Zero Direct CO₂ Emissions vs. Net-Zero Life Cycle Greenhouse Gas Emissions

In the above analysis, we looked at mitigating the direct CO₂ emissions of electricity production and supply systems. However, we also showed that even in the case of net-zero-direct-CO₂-emissions, there were still substantial GHG emissions in the background of our systems. **Figure 10** also shows that many of these background emissions stem from outside the region of study (in this case Central West Europe). This raises the question of what net-zero really means, which also relates to the question of stewardship. That is, if a country or region wants to reach net-zero at a given moment in time, should it then also compensate for indirect emissions, and should it also

compensate for emissions outside its own region, but attributable to its power supply system? Given the nature of this contribution, we will not speculate on the political or legal aspects of such questions, but we can show how the full value chain could be made climate neutral over its life cycle, and what this implies for other environmental impacts.

To completely rid our electricity production systems of all indirect CO₂-eq. emissions, an immense amount of supply chain improvements would need to be realized. In the CCS system, it would be necessary to completely eliminate methane losses during transport and natural gas production and use renewable electricity to power compression stations in both the EU as Russia. In the P-X-P systems, as materials are increasingly imported from outside of the EU, mainly China, the effort of the replacement of coal power plants with wind and PV in China becomes an essential measure in order to achieve a true net zero-emission of our electricity system. However, it would be difficult for the EU to implement or enforce such energy transition strategy outside the EU (other than through global multilateral agreements following the Paris Agreement).

Alternatively, a country or region could compensate for the emissions of its energy system outside its geographic boundaries. In the spirit of this work, one option would be to use DAC to negate all CO₂-eq. emissions left in the system. Naturally, the other environmental impacts will then further increase, because the additional DAC also needs additional energy (thus PV and wind). **Figure 12** shows the increase in environmental impacts if we increase DAC and CO₂ storage to have a system with zero life cycle GHG emissions. The energy required for DAC was expected to come from within the system itself. The increase of other environmental impacts for the unabated NGCC system is the highest among the five systems studied, with an average increase of 112% (**Figure 11**). This is due to the fact that it had the highest GHG emissions in the original system, so a higher DAC capacity is needed to negate the remaining emissions. The other impacts

of the CCS system increase on average by 21% and the P-X-P systems with 11% (meaning there is less environmental burden of making the P-X-P systems net-zero GHG over their life cycle).

There is a positive feedback loop when the GHG impact of the renewable supply is decreased, because reducing emissions in our system leads to cleaner electricity which improves our system again. This loop is taken into account and thus less direct air capture is needed compared with the situation were the background emissions of the electricity supply would have been kept stable. Battling climate change through the capture of CO₂ with DAC will be technologically possible. However, implementing it on the scale that would be necessary to completely negate the remaining GHG emissions will require a massive deployment of this technology and introduce an increase in other environmental impact categories. In the P-X-P systems this increase on non-climate change categories is up to 11%, whereas for the CCS system impact increases by 21%.

CONCLUSIONS

This study addressed the system design, sizing and life-cycle assessment of three power-to-X-to-power systems for chemical energy storage of intermitted renewable electricity. Hydrogen, methane and ammonia were assessed as potential energy carriers and all systems were designed to adhere to the net-zero-direct-CO₂-emission constraint. The LCA comparison between the P-X-P systems and two reference CCS systems (one fully abated, one unabated) on seven impact categories showed there was not a single clear winner as several trade-offs were found between them. Net-zero-direct-CO₂ P-X-P systems result in a climate change impact that is up to 50% lower than the fully abated NGCC system and has lower impacts on both photochemical ozone formation and fossil resource scarcity. The fully abated NGCC system outperformed the P-X-P systems on marine eutrophication and mineral resource scarcity where their results were comparable for particulate matter formation. Among the three P-X-P systems assessed the hydrogen system has the lowest environmental impact in all categories due to its higher round trip efficiency.

This publication has focused on the environmental impacts of net-zero CO₂ energy systems. A full economic performance was not undertaken. The system design, however, indicates that the very low capacity factors for both electrolyser and the re-electrification modules are reason to believe that the economic attractiveness of the P-X-P systems as such might be limited. The same hurdle was found in the research by Götz et al. (2016), where it is shown that synthetic natural gas cannot be expected to

compete with natural gas prices even when the electricity cost is 0 ct/kWh. In real power systems the P-X-P systems might be able to collaborate with different systems or modes of operation, thereby increasing the capacity factor and economics. An example of this could be cross-sector coupling of the energy and chemicals sector through methanol, ammonia, or another synthetically produced molecule.

Nevertheless, a system without climate change impact in its entire life cycle, including the background, was proposed and assessed. This was achieved by capturing an equal amount of CO₂ from the atmosphere in order to cancel out any background emissions that are still present in the net-zero-direct-CO₂ systems. If the systems are equipped with enough direct air capture to do this, it would logically lead to an increase in the other impact categories. This demonstrates the importance of using multiple indicators in (environmental) decision making, as it can show drawbacks of technologies otherwise overlooked. In this research we show that P-X-P systems can have a place in future zero carbon energy systems, but that it also has its trade-offs and hurdles to overcome. These trade-offs are only visible if decision making is not only focused on CO₂ emissions but also takes other impacts into account.

DATA AVAILABILITY STATEMENT

All datasets generated for this study are included in the article/**Supplementary Material**.

AUTHOR CONTRIBUTIONS

The authors together conceived the original idea. JW undertook the quantitative analysis under guidance of MS and LS. All authors contributed to authoring the manuscript and agree to its final content.

ACKNOWLEDGMENTS

This work was undertaken without external funding. JW would like to express his gratitude to Xiaojin Zhang and Christian Bauer for helping to set up the life cycle inventory for water electrolysis and methane synthesis and for their very helpful advice.

SUPPLEMENTARY MATERIAL

The Supplementary Material for this article can be found online at: <https://www.frontiersin.org/articles/10.3389/fenrg.2020.00104/full#supplementary-material>

REFERENCES

- Amprion GmbH (2018). *Flow - Based Market Coupling*. Dortmund: The company Amprion GmbH.
- Arpagaus, C., Bless, F., Uhlmann, M., Schiffmann, J., and Bertsch, S. S. (2018). High temperature heat pumps: market overview, state of the art, research status, refrigerants, and application potentials. *Energy* 152, 985–1010. doi: 10.1016/j.energy.2018.03.166
- Bai, M., Zhang, Z., and Fu, X. (2016). A review on well integrity issues for CO₂ geological storage and enhanced gas recovery. *Renew. Sustain. Energy Rev.* 59, 920–926. doi: 10.1016/j.rser.2016.01.043
- Brouwer, A. S., van den Broek, M., Seebregts, A., and Faaij, A. (2015). Operational flexibility and economics of power plants in future low-carbon power systems. *Appl. Energy* 156, 107–128. doi: 10.1016/j.apenergy.2015.06.065

- Budt, M., Wolf, D., Span, R., and Yan, J. (2016). A review on compressed air energy storage: basic principles, past milestones and recent developments. *Appl. Energy* 170, 250–268. doi: 10.1016/j.apenergy.2016.02.108
- Bussar, C., Stöcker, P., Cai, Z., Moraes, L. Jr., Magnor, D., Wiernes, P., et al. (2016). Large-scale integration of renewable energies and impact on storage demand in a European renewable power system of 2050—sensitivity study. *J. Energy Storage* 6, 1–10. doi: 10.1016/j.est.2016.02.004
- Carmo, M., Fritz, D. L., Mergel, J., and Stolten, D. (2013). A comprehensive review on PEM water electrolysis. *Int. J. Hydrogen Energy* 38, 4901–4934. doi: 10.1016/j.ijhydene.2013.01.151
- Corsten, M., Ramirez, A., Shen, L., Koornneef, J., and Faaij, A. (2013). Environmental impact assessment of CCS chains - Lessons learned and limitations from LCA literature. *Int. J. Greenhouse Gas Control* 13, 59–71. doi: 10.1016/j.ijggc.2012.12.003
- CWE NRAs (2015). *Position Paper of CWE NRAs on Flow - Based Market Coupling*. CWE NRAs Creg 1–15.
- Davis, S. J., Lewis, N. S., Shaner, M., Aggarwal, S., Arent, D., Azevedo, I. L., et al. (2018). Net-zero emissions energy systems. *Science* 360:9793. doi: 10.1126/science.aas9793
- DBI-GUT (2017). *The Effects of Hydrogen Injection in Natural Gas Networks for the Dutch Underground Storages*, 74. Retrieved from at: <https://www.rvo.nl/sites/default/files/2017/07/The%20effects%20of%20hydrogen%20injection%20in%20natural%20gas%20networks%20for%20the%20Dutch%20underground%20storages.pdf> (accessed May 27, 2020).
- Dones, R., Heck, T., Emmenegger, M. F., and Jungbluth, N. (2005). Life cycle inventories for the nuclear and natural gas energy systems, and examples of uncertainty analysis. *Int. J. Life Cycle Assess* 10, 10–23. doi: 10.1065/lca2004.12.181.2
- European Commission (2012). *Energy Roadmap 2050?* Luxembourg: Publications Office of the European Union.
- European Commission (2016). *EU Reference Scenario 2016 - Energy, Transport and GHG Emissions - Trends to 2050*. *Energy, Transport and GHG Emissions - Trends to 2050*. doi: 10.2833/9127
- European Commission (2018). *European Commission Quarterly Report on European Electricity Markets*. European Commission.
- European Commission (2019). *The European Green Deal*. European Commission. doi: 10.1017/CBO9781107415324.004
- FCH JU (2015). *Commercialisation of Energy Storage*. FCH JU.
- Gas Infrastructure Europe (2018). *NG Storage Database*. Available online at: <https://www.gie.eu/index.php/gie-publications/databases/storage-database> (accessed on December 15, 2019).
- Götz, M., Lefebvre, J., Mörs, F., McDaniel Koch, A., Graf, F., Bajohr, S., et al. (2016). Renewable power-to-gas: a technological and economic review. *Renew. Energy* 85, 1371–1390. doi: 10.1016/j.renene.2015.07.066
- Grinberg Dana, A., Elishav, O., Bardow, A., Shter, G. E., and Grader, G. S. (2016). Nitrogen-based fuels: a power-to-fuel-to-power analysis. *Angew. Chem. Int. Ed.* 55, 8798–8805. doi: 10.1002/anie.201510618
- Haeseldonckx, D., and D'haeseleer, W. (2007). The use of the natural-gas pipeline infrastructure for hydrogen transport in a changing market structure. *Int. J. Hydrogen Energy* 32, 1381–1386. doi: 10.1016/j.ijhydene.2006.10.018
- Hertwich, E. G., Gibon, T., Bouman, E. A., Arvesen, A., Suh, S., Heath, G. A., et al. (2014). Integrated life-cycle assessment of electricity-supply scenarios confirms global environmental benefit of low-carbon technologies. *Proc. Natl. Acad. Sci. U.S.A.* 112, 6277–6282. doi: 10.1073/pnas.1312753111
- Heuberger, C. F., Staffell, I., Shah, N., and Mac Dowell, N. (2016). Quantifying the value of CCS for the future electricity system. *Energy Environ. Sci.* 9, 2497–2510. doi: 10.1039/C6EE01120A
- Huijbregts, M. A. J., Steinmann, Z. J. N., Elshout, P. M. F., Stam, G., Veronesi, F., Vieira, M. D. M., et al. (2016). ReCiPe 2016: A harmonized life cycle impact assessment method at midpoint and endpoint level - Report 1 : characterization. *National Institute for Public Health and the Environment*. doi: 10.1007/s11367-016-1246-y
- Hutchings, G. J. (2002). Methanation of carbon dioxide. *Appl. Catal. A Gen.* 84, 103–190. doi: 10.1016/0926-860X(92)80119-W
- HyUnder (2014). *Assessment of the Potential, the Actors and Relevant Business Cases for Large Scale and Seasonal Storage of Renewable Electricity by Hyrdrogen Underground Storage in Europe*. HyUnder.
- IEA (2012). *CO₂ Capture at Gas Fired Power*. IEAGHG.
- Institute for Sustainable Process Technology (2017). *Power to Ammonia Report*. Institute for Sustainable Process Technology. Available online at: <https://ispt.eu/media/DR-20-09-Power-to-Ammonia-2017-publication.pdf> (accessed May 27, 2020)
- IPCC (2014). “Summary for policy makers,” in *Climate Change 2014: Synthesis Report. Contribution of Working Groups I, II and III to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*, eds R. K. Core Writing Team Pachauri and L. A. Meyer (Geneva: IPCC), 151.
- IPCC (2018). “Summary for policymakers,” in *Global Warming of 1.5°C. An IPCC Special Report on the Impacts of Global Warming of 1.5°C Above Pre-Industrial Levels and Related Global Greenhouse Gas Emission Pathways, in the Context of Strengthening the Global Response to the Threat of Climate Change*, eds T. W. V. Masson-Delmotte et al. (Geneva: IPCC), 32.
- ISO (2006). *LCA Standards*. Available online at: <https://www.iso.org/obp/ui/#iso:std:iso:14044:ed-1:v1:en> (accessed May 27, 2020).
- Kobayashi, H., Hayakawa, A., Somarathne, K. D. K. A., and Okafor, E. C. (2019). Science and technology of ammonia combustion. *Proc. Combust. Inst.* 37, 109–133. doi: 10.1016/j.proci.2018.09.029
- Kurata, O., Iki, N., Inoue, T., Matsunuma, T., Tsujimura, T., Furutani, H., et al. (2019). Development of a wide range-operable, rich-lean low-NO_x combustor for NH₃ fuel gas-turbine power generation. *Proc. Combust. Inst.* 37, 4587–4595. doi: 10.1016/j.proci.2018.09.012
- Mac Dowell, N., Fennell, P. S., Shah, N., and Maitland, G. C. (2017). The role of CO₂ capture and utilization in mitigating climate change. *Nat. Clim. Change* 7, 243–249. doi: 10.1038/nclimate3231
- Michalski, J., Bünger, U., Crotogino, F., Donadei, S., Schneider, G.-S., Pregger, T., et al. (2017). Hydrogen generation by electrolysis and storage in salt caverns: potentials, economics and systems aspects with regard to the German energy transition. *Int. J. Hydrogen Energy* 42, 13427–13443. doi: 10.1016/j.ijhydene.2017.02.102
- Mletzko, J., Ehlers, S., and Kather, A. (2016). Comparison of natural gas combined cycle power plants with post combustion and oxyfuel technology at different CO₂ capture rates. *Energy Procedia* 86, 2–11. doi: 10.1016/j.egypro.2016.01.001
- Müller, B., Müller, K., Teichmann, D., and Arlt, W. (2011). Energiespeicherung mittels Methan und energietragenden Stoffen ein thermodynamischer Vergleich. *Chem. Ingenieur-Technik* 83, 2002–2013. doi: 10.1002/cite.201100113
- Niaz, S., Manzoor, T., and Pandith, A. H. (2015). Hydrogen storage: materials, methods and perspectives. *Renew. Sustain. Energy Rev.* 50, 457–469. doi: 10.1016/j.rser.2015.05.011
- Nozari, H., and Karabeyoğlu, A. (2015). Numerical study of combustion characteristics of ammonia as a renewable fuel and establishment of reduced reaction mechanisms. *Fuel* 159, 223–233. doi: 10.1016/j.fuel.2015.06.075
- Oliveira, L., Messaggi, M., Mertens, J., Laget, H., Coosemans, T., and van Mierlo, J. (2015). Environmental performance of electricity storage systems for grid applications, a life cycle approach. *Energy Conversion Manage.* 101, 326–335. doi: 10.1016/j.enconman.2015.05.063
- Pfenninger, S., and Staffell, I. (2016). Long-term patterns of European PV output using 30 years of validated hourly reanalysis and satellite data. *Energy* 114, 1251–1265. doi: 10.1016/J.ENERGY.2016.08.060
- Reiter, G., and Lindorfer, J. (2015). Global warming potential of hydrogen and methane production from renewable electricity via power-to-gas technology. *Int. J. Life Cycle Assess.* 20, 477–489. doi: 10.1007/s11367-015-0848-0
- Rodríguez, R. A., Becker, S., Andresen, G. B., Heide, D., and Greiner, M. (2014). Transmission needs across a fully renewable European power system. *Renew. Energy* 63, 467–476. doi: 10.1016/j.renene.2013.10.005
- Schmidt, O., Gambhir, A., Staffell, I., Hawkes, A., Nelson, J., and Few, S. (2017). Future cost and performance of water electrolysis: an expert elicitation study. *Int. J. Hydrogen Energy* 42, 30470–30492. doi: 10.1016/j.ijhydene.2017.10.045
- Singh, B., Strömman, A. H., and Hertwich, E. (2011). Life cycle assessment of natural gas combined cycle power plant with post-combustion carbon capture, transport and storage. *Int. J. Greenhouse Gas Control* 5, 457–466. doi: 10.1016/j.ijggc.2010.03.006
- Staffell, I., and Pfenninger, S. (2016). Using bias-corrected reanalysis to simulate current and future wind power output. *Energy* 114, 1224–1239. doi: 10.1016/J.ENERGY.2016.08.068
- Sutter, D., van Der Spek, M., and Mazzotti, M. (2019). 110th Anniversary: evaluation of CO₂-based and CO₂-free synthetic fuel systems using a

- net-zero-CO₂-emission framework. *Ind. Eng. Chem. Res.* 58, 19958–19972. doi: 10.1021/acs.iecr.9b00880
- US Department of Energy (2017). *Fuel Cell Technology Offices Multi-Year Research, Development, and Demonstration Plan*: US Department of Energy.
- Valera-Medina, A., Xiao, H., Owen-Jones, M., David, W. I. F., and Bowen, P. J. (2018). Ammonia for power. *Progress Energy Combust. Sci.* 69, 63–102. doi: 10.1016/j.pecs.2018.07.001
- van Der Spek, M., Bonalumi, D., Manzolini, G., Ramirez, A., and Faaij, A. (2018). Techno-economic comparison of combined cycle gas turbines with advanced membrane configuration and monoethanolamine solvent at part load conditions. *Energy Fuels* 32, 625–645. doi: 10.1021/acs.energyfuels.7b02074
- Vojvodic, A., Medford, A. J., Studt, F., Abild-Pedersen, F., Khan, T. S., Bligaard, T., et al. (2014). Exploring the limits: a low-pressure, low-temperature Haber-bosch process. *Chem. Phys. Lett.* 598, 108–112. doi: 10.1016/j.cplett.2014.03.003
- Weidema, Bo. P. (2018). *Attributional and Consequential Interpretations of the ISO 14044*. Berlin.
- Wohland, J., Witthaut, D., and Schleussner, C. F. (2018). Negative emission potential of direct air capture powered by renewable excess electricity in Europe. *Earth's Future* 6, 1380–1384. doi: 10.1029/2018EF000954
- Yapicioglu, A., and Dincer, I. (2019). A review on clean ammonia as a potential fuel for power generators. *Renew. Sustain. Energy Rev.* 103, 96–108. doi: 10.1016/j.rser.2018.12.023
- Zappa, W., Junginger, M., and van den Broek, M. (2019). Is a 100% renewable European power system feasible by 2050? *Appl. Energy* 233–234, 1027–1050. doi: 10.1016/j.apenergy.2018.08.109
- Zhang, X., Bauer, C., Mutel, C. L., and Volkart, K. (2017). Life cycle assessment of power-to-gas: approaches, system variations and their environmental implications. *Appl. Energy* 190, 326–338. doi: 10.1016/j.apenergy.2016.12.098

Conflict of Interest: The authors declare that the research was conducted in the absence of any commercial or financial relationships that could be construed as a potential conflict of interest.

Copyright © 2020 Wevers, Shen and van der Spek. This is an open-access article distributed under the terms of the Creative Commons Attribution License (CC BY). The use, distribution or reproduction in other forums is permitted, provided the original author(s) and the copyright owner(s) are credited and that the original publication in this journal is cited, in accordance with accepted academic practice. No use, distribution or reproduction is permitted which does not comply with these terms.